



भा.कृ.अनु.प.- राष्ट्रीय अनार अनुसंधान केन्द्र, सोलापुर  
**ICAR - National Research Centre on Pomegranate**  
(Indian Council of Agricultural Research)  
NH-65, Solapur-Pune Highway, Kegaon, Solapur-413 255 (M.S.)  
T-(0217) 2354330, 2350074, 2350263, F-(0217) 2353533  
E mail- nrcpomegranate@gmail.com, Website- nrcpomegranate.icar.gov.in  
(ISO 9001:2015 Certified Institute)



F. No. 57-16/UPS 10 KVA/RKVY/BCL/23

Dated: 13.03.2024

**TECHNICAL SPECIFICATION CORRIGENDUM**

With reference to this office tender/bid vide no. GEM/2024/B/4746920 dated 07.03.2024 for supply and installation of 10 KVA UPS, it is to inform that the Technical Specification mentioned at point no. 5 of Annexure-I of the tender document must be read as follows:

Sl. No.	Specification Name	Existing Requirement/Specification	Modified Requirement/Specification
5.	Output Voltage	AC Single phase 230V +/-1% 50 Hz / AC 3 phase 415V having a variable setting the range starting from 380 volt - variable upto to 415 volt /AC 3 Phase 400V +/-1% with alternative user setable setting of 380V +/-1% 50 Hz/	AC 3 phase 415V having a variable setting the range starting from 380 volt - variable upto to 415 volt /AC 3 Phase 400V +/-1% with alternative user setable setting of 380V +/-1% 50 Hz/

This is issued with the approval of the Director, ICAR-NRCP, Solapur.

  
**ADMINISTRATIVE OFFICER**